

# Certificate

Registration No.: PV 60039387

Page 1

Report No.: 21169471.001

**License Holder:**

**Scheuten Solar Logistics B.V.**

Van Heemskerckweg 30

5928 LL Venlo

The Netherlands

**Manufacturing plant:**

Scheuten Solar Technology GmbH

Scheuten-Solar-Straße 2

45842 Gelsenkirchen

Germany

**Product:**

PV Modules

**Type:**

Multisol® P6-66, Multisol® M6-66

(power range 225-265 Wp in steps of 5 Wp)

Multisol® P6-60, Multisol® M6-60

(power range 200-240 Wp in steps of 5 Wp)

Multisol® P6-54

(power range 180-210 Wp in steps of 5 Wp)

Multisol® M6-54

(power range 185-215 Wp in steps of 5 Wp)

Multisol® P6-48, Multisol® M6-48

(power range 160-195 Wp in steps of 5 Wp)

Multisol® P5-96

(power range 200-235 Wp in steps of 5 Wp)

Multisol® M5-96

(power range 210-250 Wp in steps of 5 Wp)

**Basis:**

- IEC 61730-1:2004**  
**IEC 61730-2:2004**  
**EN 61730-1:2007**  
**EN 61730-2:2007**  
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**  
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic inspection

**Remarks:**

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The above listed PV modules fulfil the requirements of **fire rating class C**.
- The details of the factory inspection are documented in report no.: 21214886.

**Conditions:**

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

**The certificate is valid until 10 August 2014.**



Cologne, 27 May 2011

Dipl.-Ing. M. Adrian

# Certificate

Registration No.: PV 60039387

Page 2

Report No.: 21169471.001

**License Holder:**

**Scheuten Solar Logistics B.V.**

Van Heemskerckweg 30

5928 LL Venlo

The Netherlands

**Product:**

PV Modules

**Type:**

Multisol® P6-66, Multisol® M6-66  
(power range 225-265 Wp in steps of 5 Wp)

Multisol® P6-60, Multisol® M6-60  
(power range 200-240 Wp in steps of 5 Wp)

Multisol® P6-54  
(power range 180-210 Wp in steps of 5 Wp)

Multisol® M6-54  
(power range 185-215 Wp in steps of 5 Wp)

Multisol® P6-48, Multisol® M6-48  
(power range 160-195 Wp in steps of 5 Wp)

Multisol® P5-96  
(power range 200-235 Wp in steps of 5 Wp)

Multisol® M5-96  
(power range 210-250 Wp in steps of 5 Wp)

**Manufacturing plant:**

Scheuten Optisol B.V.

Van Heemskerckweg 30

5928 LL Venlo

The Netherlands

**Basis:**

- IEC 61730-1:2004  
IEC 61730-2:2004  
EN 61730-1:2007  
EN 61730-2:2007  
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**  
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic inspection

**Remarks:**

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.
- The above listed PV modules fulfil the requirements of fire rating class C.
- The details of the factory inspection are documented in report no.: 21211829.

**Conditions:**

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

**The certificate is valid until 10 August 2014.**



Cologne, 27 May 2011

Dipl.-Ing. M. Adrian