

Certificate

Registration No.: PV 60033420

Page 1

Report No.: 21154181.001

License Holder:

SOLON SE
Am Studio 16
12489 Berlin
Germany

Product:

PV Module
Type:
SOLON Blue 270/12,
SOLON Black 280/12

Manufacturing Plant:

SOLON Photovoltaik GmbH
Am Studio 16
12489 Berlin
Germany

Basis:

- IEC 61730-1:2004**
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 21214564.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 23 July 2015.

Cologne, 24 August 2010



Dipl.-Ing. M. Adrian

Certificate

Registration No.: PV 60033420

Page 2

Report No.: 21154180.001

License Holder:

SOLON SE

Am Studio 16
12489 Berlin
Germany

Product:

PV Module

Type:

SOLON Blue 270/12,
SOLON Black 280/12

Manufacturing Plant:

SOLON Nord GmbH

Siemensallee 1
17489 Greifswald
Germany

Basis:

- IEC 61730-1:2004**
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 21214563.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 23 July 2015.

Cologne, 24 August 2010



Dipl.-Ing. M. Adrian

Certificate

Registration No.: PV 60033420

Page 3

Report No.: 21154180.001

License Holder:

SOLON SE
Am Studio 16
12489 Berlin
Germany

Product:

PV Module

Type:

SOLON Blue 270/12,
SOLON Black 280/12

Manufacturing Plant:

SOLON SpA
Via dell'Industria e dell'Artigianato 22 D
35010 Carmignano di Brenta (PD)
Italy

Basis:

- IEC 61730-1:2004**
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 21214567.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 23 July 2015.

Cologne, 24 August 2010



Dipl.-Ing. M. Adrian

Certificate

Registration No.: PV 60033420

Page 4

Report No.: 21154180.001

License Holder:

SOLON SE
Am Studio 16
12489 Berlin
Germany

Product:

PV Module
Type:
SOLON Blue 270/12,
SOLON Black 280/12

Manufacturing Plant:

SOLON Corporation
6959 South Country Club Road
Tucson, Arizona 85756
USA

Basis:

- IEC 61730-1:2004**
IEC 61730-2:2004
EN 61730-1:2007
EN 61730-2:2007
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**
To document the consistent quality of the product factory inspections are performed periodically.



- Qualified, IEC 61215
- Safety tested, IEC 61730
- Periodic Inspection

Remarks:

- IEC EN 61730 consists of part 1 (Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 21211265.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.

The certificate is valid until 23 July 2015.



Cologne, 24 August 2010

Dipl.-Ing. M. Adrian